

ControlPlex[®] Rack Installation Instruction



Date of issue:

Date of publication: May 2017

This document replaces the following documents:

„**ControlPlex® Rack** I_19BGTCP_d_200916

Editor:

E-T-A Elektrotechnische Apparate GmbH
Industriestraße 2-8 · 90518 ALTDORF
GERMANY
Tel. +49 9187 10-0 · Fax +49 9187 10-397
E-Mail: info@e-t-a.de · www.e-t-a.de

Copyright © 2017 E-T-A GmbH

The contents of this document are the property of E-T-A GmbH. No part of this publication must in any way be reproduced or distributed without prior written consent of E-T-A GmbH. Any person acting illegally with regard to this publication can be prosecuted.

Limitation of liability

Although all provisions were taken when creating this document, the editor does not accept any responsibility for errors or omissions or for damages caused by using the information contained in this document. The information contained in this document may be revised at any time without pre-advice.

Brands

All references to software and hardware in this document are generally protected by brands or patents.

© E-T-A GmbH 2017. All rights reserved

About this manual

This manual describes the electrical start-up of the **ControlPlex® Rack** system in connection with compatible **ControlPlex® Rack** components. The **ControlPlex® Rack** allows artless and reliable protection and monitoring of minus-supplied systems. Typical applications include telecommunications as well as IT centres, e.g. the protection and electrical monitoring of server or router cabinets.

Besides this document, more information about the E-T-A **ControlPlex® Rack** can be found in the following documents.

ControlPlex® Rack

Data sheet

Here you will find more technical data and figures as well as approval information on the various components of the **ControlPlex® Rack** system

ControlPlex® Rack

Operation instruction manual RCI10

Here you will find an instruction for configuration and for integration of the module Remote Control Interface **RCI10** into your network. In addition this document holds a user description of the web browser and the SSH surface as well as the SNMP MIB for integration into a management system.

ControlPlex® Rack

Release Notes RCI10_SW_V2.0 Here you will find the information of the extended performance features of the current software for the **RCI10** sub-assembly.

ControlPlex® Rack

Application examples EAI300 Here you will find further configuration and connection examples for the **EAI300** module

The latest documents can be found on our website under www.e-t-a.de/controlplex_rack

All documents contain important instructions for connection and safe operation of the **ControlPlex® Rack** system. Safety instructions have to be observed. All users have to be informed about all safety instructions. The documents have to be accessible for the user.

Contents

About this manual	3
Contents	4
General note	6
1 Introduction	8
2 Minimal requirements of installation.....	9
3 General: ControlPlex® Rack Power-D-Box®	10
3.1 Use of the <i>Power-D-Box</i> ®	10
3.2 Technical data of the <i>Power-D-Box</i> ®	11
3.3 Scope of delivery of the <i>Power-D-Box</i> ®	12
3.4 Pictures of <i>Power-D-Box</i> ® versions (front view).....	12
3.5 Drawings and dimensions of <i>Power-D-Box</i> ® versions.....	13
3.6 Schematic diagrams of <i>Power-D-Box</i> ® versions	15
3.7 Pin assignment of <i>Power-D-Box</i> ® versions	16
3.8 Installation and start-up of the <i>Power-D-Box</i> ®	18
3.8.1 Recommended installation site for <i>Power-D-Box</i> ®	18
3.8.2 Basic notes on cabling for <i>Power-D-Box</i> ®	18
3.8.3 Mounting and start-up of <i>Power-D-Box</i> ®	19
4 General: ControlPlex® Rack, electronic circuit protector ESX300-S	21
4.1 Application ESX300-S.....	21
4.2 Technical data of the <i>Power-D-Box</i> ®	21
4.2.1 Current rating, voltage drop and load capacity of ESX300-S	22
4.2.2 LED status indication	22
4.3 Delivery scope ESX300-S	22
4.4 Picture ESX300-S.....	23
4.5 Installation and start-up ESX300-S.....	23
4.6 Removal of the electronic circuit protector ESX300-S	25
4.7 Trouble-shooting concerning electronic circuit protector ESX300-S.....	26
5 General: ControlPlex® Rack, signalling sub-assembly RSI10.....	27
5.1 Application RSI10	27
5.2 Technical data of RSI10	27
5.2.1 Operating conditions and LED indication	28
5.3 Delivery scope RSI10.....	28
5.4 Picture of RSI10	29
5.5 Installation and start-up RSI10	29

6	General: <i>ControlPlex</i>® Rack, control interface RCI10	30
6.1	Application RCI10	30
6.2	Technical data of RCI10	30
6.2.1	Momentary switch function and LED status indication	32
6.2.2	Function IP-reset by pressing the reset button with LED display.....	33
6.3	Delivery scope RCI10.....	33
6.4	Picture of RCI10.....	33
6.5	Installation and start-up RCI10	34
6.5.1	Picture of slot for RCI10 or RSI10	35
6.5.2	Picture of an example for network connection.....	35
6.6	Configuration and start-up RCI10.....	35
7	General: <i>ControlPlex</i>® Rack, E/A external alarm interface EAI300	36
7.1	Operating mode and application EAI300	36
7.2	Technical data of EAI300.....	36
7.2.1	Operating conditions LED signalling.....	37
7.3	Delivery scope EAI300	37
7.4	Picture EAI300.....	37
7.5	Installation and connection EAI300.....	38
7.5.1	Example: EAI300 slot configuration.....	39
7.5.2	EAI300 pin assignment and connection example	39
7.6	Configuration and start-up EAI300	39

General note

Qualified personnel

The system must only be installed, connected and configured in connection with this document. Installation and operation of the device/system must only be carried out by qualified personnel. With regard to the safety instructions of this documentation, qualified persons are persons authorised to operate devices, systems and circuits according to the standards and rules of safety engineering.

Safety instructions



Please follow the installation and configuration instructions given in this document carefully. Failure to comply may lead to serious damages of the product or the system. E-T-A does not accept any liability for problems caused by improper installation or handling by the customer or a third person.

Symbols

You will find the following symbols in the entire manual. Their meaning is as follows:



Danger!

You are in a situation which might cause injury. Before working with one of the devices you have to be aware of the risks of electrical circuitries and you ought to be familiar with standard procedures of accident prevention.



Warning

There is a risk in this situation to do something which might cause damage of the devices or data loss.



Note

Here you receive information which might be particularly useful for the application.



Caution:

Electrostatically sensitive devices (ESD). Devices must exclusively be opened by the manufacturer.

1 Introduction

You chose **ControlPlex® Rack**, a comprehensive, future-oriented protection system which combines safety, user convenience and service friendliness. It is a power distribution and management system which provides electronic and, in the event of a short circuit, current-limiting protection of various loads. By means of an internal bus system and an additional, hot-pluggable control interface module (optional), each load can remotely be controlled and monitored. In addition it allows recording of measuring data of every single load. Besides providing overcurrent and short circuit protection, it increases system availability by a multiple, because it disconnects faulty loads quickly, selectively and without voltage dips.

In connection with the control interface module type RCI10 the **ControlPlex® Rack** system can be connected to a centralised management system (control computer). For this purpose an Ethernet interface is made available with SNMP v1, v2c or v3 protocol. The required private MIB for embedding is part of the delivery scope. An additional possibility for a centralised or also local monitoring/control is provided by the integral web server, which can be used without additional software on the control computer by means of the web browser.

Thanks to its system properties the **ControlPlex® Rack** is the perfect solution for smart protection, control and energy measurement for DC-supplied minus switching system cabinets. Typical applications include:

- System cabinets of any kind in telecommunications with DC -48 V or DC -60 V rated supply
- Server cabinets in IT centres with equipment for DC -48 V or DC -60 V rated supply
- System cabinets for mobile radio and television for DC -40 V to DC -72 V
- Protection and control of illuminated advertising with a power supply of DC -48 V

Further descriptions of the **ControlPlex® Rack** system with information on the configuration and network connection by means of the module control interface RCI10 are available in the Operation instruction RCI10 manual **ControlPlex® Rack**.

This document contains the mounting and connection procedures for the hardware of the **ControlPlex® Rack** system as well as an instruction for the first operation. You will learn more about

- how to mount and connect the different **ControlPlex® Rack Power-D-Box®** versions
- how to start up or exchange the electronic circuit protectors type ESX300-S
- how to identify and remedy failures of the electronic circuit protectors ESX300-S
- how to install and connect the optional control interface RCI10
- how to identify and remedy failures of the control interface RCI10 by means of LED indication
- how to install and connect the E/A external alarm interface EAI300.
- how to identify failures of the EAI300 by means of LED indication.

2 Minimal requirements of installation

Please check the delivered components upon receipt with regard to completeness. You require the following hardware components for installation and start-up of the **ControlPlex® Rack** system:

- One or more **Power-D-Box®** modules type: PDB-N-CP
- Electronic circuit protectors type ESX300-S-x00-xx A (version e.g.: with aux. contact only for PDB-N-CP-xxx-xx-S, old version) or with bus interface; various current ratings: 2 A...24 A
- Optional: control interface with Ethernet interface type RCI10-000-x. The circuit protector type ESX300-S-300-xxA is mandatory for use with control interface and signalling sub-assemblies RSI10.
- Optional: Alarm interface EAI300 for including additional “external” alarm contacts. Operation of EAI300 sub-assemblies requires control interface RCI10.

In addition you require different cables for connection of the **Power-D-Box®**, of the supply line, the loads and the ground. Many manufacturers offer standard cables for this purpose.

2.1 Important information and safety instructions

The following table lists various information and safety instructions for start-up and use of the device.







	Danger: Installation and operation of the device This device has to be installed and operated in compliance with the given instructions. Failure to comply can lead to injury, damage of loads or of the ControlPlex® Rack system.
	Danger: Turn off the supply voltage Before beginning with installation, the system has to be disconnected from the mains. A cable connection must only be established if the supply voltage is OFF.
	Danger: Possible ignition hazard The device must NOT be used in inflammable surroundings.
	Danger: high voltage The cover must NEVER be opened. Access to the inner components is not allowed unless indicated otherwise in this manual.
	Caution: Work with ESD protection Electronic modules must only be touched and installed with ESD protection so as to ensure protection against electrostatic voltage. Failure to comply can cause damages on the ControlPlex® Rack system or the corresponding components.
	Warning: Grounding The device must be grounded before switching on.

Table 1: Important information

2.12 EMC installation directives

The **ControlPlex® Rack** hardware and accessories comply with the EMC directives. Thus electromagnetic interferences between the devices are avoided which would otherwise affect the system performance. A professional installation is mandatory. In order to ensure the best EMC conditions, the widest possible distance between the different electrical devices should be applied.

2.3 Technical Accuracy

All technical data in this manual were correct in all conscience at the time of printing. E-T-A cannot be held liable for any (inadvertent) errors. Due to continuous product improvements at E-T-A there could be discrepancies between the actual product and the manual. Product changes or amendments of the technical specifications will be carried out without prior notification. The latest versions of the **ControlPlex® Rack** documents are available on our website (www.e-t-a.de).

3 General: ControlPlex® Rack Power-D-Box®

By using the **Power-D-Box®** type PDB-N-CPxxx-xx-A you can benefit from the advantages of the **ControlPlex® Rack** system to full extent, no matter whether the control interface RCI10 is used from the start or only later.

3.1 Use of the Power-D-Box®

The **ControlPlex® Rack Power-D-Box®** has been designed for the quick and easy installation into 19" or ETSI racks which is ensured by a rotating mounting flange. Depending on the required termination technology (front or rear) the corresponding **Power-D-Box®** will be available as a product. The service friendliness has to be mentioned as a special advantage. The system can be extended with power on and additional circuit protectors can be plugged into the load terminals. The control interface can also be fitted later with power on without having to disconnect the loads.

3.2 Technical data of the *Power-D-Box*[®]

The entire 19" rack features the protection degree IP20. Table 2 summarizes the vital information.

Electrical data	PDB-N-CP09A-RR-A	PDB-N-CP09A-RF-A	PDB-N-CP09A-FF-A	PDB-N-CP19A-RR-A	PDB-N-CP18R-RR-A
Operating voltage	DC -48 V or DC -60 V	DC -48 V or DC -60 V	DC -48 V or DC -60 V	DC -48 V or DC -60 V	DC -48 V or DC -60 V
Max. supply current:	150 A	150 A	100 A	200 A	2 x 150 A
number of circuit protectors	9	9	9	19	18
Redundant system	no	no	no	no	yes
Protected pole	Negative pole protected electronically, without physical isolation				
Suitable for circuit protector	ESX300-S-3xx (2 A, 5 A, 8 A, 12 A, 16 A, 20 A, 24 A, with BUS)				
Ambient temperature	-20...+60 °C				
Mechanical data	PDB-N-CP09A-RR-A	PDB-N-CP09A-RF-A	PDB-N-CP09A-FF-A	PDB-N-CP19A-RR-A	PDB-N-CP18R-RR-A
Dimensions	see drawings and dimensions				
Mounting method	4 mounting screws M6 x 16 mm (not supplied with product) tightening torque 5.3...5.7 Nm				
Supply	PDB-N-CP09A-RR-A	PDB-N-CP09A-RF-A	PDB-N-CP09A-FF-A	PDB-N-CP19A-RR-A	PDB-N-CP18R-RR-A
Terminals	on the rear	on the rear	on the front	on the rear	on the rear
Screw terminals	16 – 50 mm ² AWG 5 – AWG 1	16 – 50 mm ² AWG 5 – AWG 1	4 – 25 mm ² AWG 11 – AWG 3	16 – 50 mm ² AWG 5 – AWG 1	16 – 50 mm ² AWG 5 – AWG 1
Tightening torque	6...8 Nm	6...8 Nm	4 ...4.5 Nm	6...8 Nm	6...8 Nm
Loads	PDB-N-CP09A-RR-A	PDB-N-CP09A-RF-A	PDB-N-CP09A-FF-A	PDB-N-CP19A-RR-A	PDB-N-CP18R-RR-A
Max. load current per load terminal	30 A with 9 ways	30 A with 9 ways	30 A with 9 ways	30 A with 19 ways	30 A with 2 x 9 ways
Terminals	on the rear	on the front	on the front	on the rear	on the rear
Screw terminals	0.5 – 6 mm ² AWG 20 – AWG 10	–	–	0.5 – 6 mm ² AWG 20 – AWG 10	0.5 – 6 mm ² AWG 20 – AWG 10
SUB-D connector	–	2.5 – 10 mm ² AWG 13 – AWG 7	2.5 – 10 mm ² AWG 13 – AWG 7	–	–
Tightening torque	0.5...0.8 Nm	–	–	0.5...0.8 Nm	0.5...0.8 Nm
Signalling	PDB-N-CP09A-RR-A	PDB-N-CP09A-RF-A	PDB-N-CP09A-FF-A	PDB-N-CP19A-RR-A	PDB-N-CP18R-RR-A
Terminals	on the rear	on the front	on the front	on the rear	on the rear
Screw terminals	0.25 – -1.5 mm ² AWG 23 – AWG 16	–	–	0.25 – 1.5 mm ² AWG 23 – AWG 16	0.25 – 1.5 mm ² AWG 23 – AWG 16
SUB-D connector	–	2.5 – 10 mm ² AWG 13 – AWG 7	2.5 – 10 mm ² AWG 13 – AWG 7	–	–
Tightening torque	0.22...0.25 Nm	–	–	0.22...0.25 Nm	0.22...0.25 Nm
Grounding	PDB-N-CP09A-RR-A	PDB-N-CP09A-RF-A	PDB-N-CP09A-FF-A	PDB-N-CP19A-RR-A	PDB-N-CP18R-RR-A
Ground connector	M6 ground stud, always on the rear, tightening torque 6 Nm				

Table 2: A selection of technical data / *) further information can be found in the data sheet.

3.3 Scope of delivery of the *Power-D-Box*[®]

The following parts are part of the delivery scope of the *Power-D-Box*[®]:

- 19" rack with 19" / ETSI interchangeable flange (mounted 19")
- blanking pieces for slots of circuit protectors and control interface (mounted)
- mating plugs in the event of rear screw terminals (plugged on). Versions: PDB-N-CPxxx-xR-Ax
- mating plugs of signalling terminals (screwed on). Versions: PDB-N-CPxxx-xR-Ax

The following accessories can be ordered separately:

- rear cable grip rail (part no. X223 260 01)
- connector set, high current SUB-D for load terminal on the front (part no. X223 189 01)
- marking frame with labels, 0.5U, for customised marking of circuit protectors (part no. X22357501)
- marking frame with labels, 1U with cable gland on the front, for customised marking of circuit protectors (part no. X22357601)
- circuit protectors, type ESX300-S-3xx-xxA
- signalling sub-assembly RSI10-xxx-x
- control interface type RCI10-xxx-x
- control alarm interface type EAI300-xxx-x

For more information on accessories please see the data sheet of *ControlPlex*[®] Rack.

3.4 Pictures of *Power-D-Box*[®] versions (front view)



fig. 1: front view PDB-N-CP18R-RR-A, PDB-N-CP19A-RR-Ax



fig. 2: front view PDB-N-CP09A-RR-Ax



fig. 3: front view PDB-N-CP09A-FF-Ax terminals on the front with high current SUB-D connectors

3.5 Drawings and dimensions of *Power-D-Box*® versions




fig. 4: front view PDB-N-CP09A-FF-Ax 1 x 9 slots, terminals on the front with high current SUB-D connectors




fig. 5: rear view PDB-N-CP09A-FF-Ax 1 x 9 slots (with rear cable grip rail)




fig. 6: front view PDB-N-CP19A-RR-Ax 1 x 19 slots




fig. 7: rear view DB-N-CP19A-RR-Ax without cable grip




fig. 8: front view PDB-N-CP18R-RR-Ax 2 x 9 slots




fig. 9: front view PDB-N-CP18R-RR-Ax 2 x 9 slots




fig. 10: top view PDB-N-CP18R-RR-Ax 2 x 9 slots (with rear cable grip rail)

3.6 Schematic diagrams of *Power-D-Box*[®] versions




fig. 11: Schematic diagram PDB-N-CP19A-RR-Ax, 1 x 19 slots with signalling




fig. 12: Schematic diagram PDB-N-CP18R-RR-Ax, 2 x 9 slots with signalling

3.7 Pin assignment of *Power-D-Box*® versions

pin assignment PDB-N-CP09A-RR-Ax, PDB-N-CP18R-RR-Ax

- Rear-side supply terminals DC 48 V–DC 60 V / max. 2 x 150 A
- Cable cross section max. 50 mm²




fig.13 version PDB-N-CP18R-RR-A, pin assignment (cable grip removed)

Pin assignment PDB-N-CP09A-FF-Ax

- Front-side supply terminals DC 48 V–DC 60 V / max. 100 A
- Cable cross section max. 25 mm²
- Front-side supply terminals A1 ... A9 DC 48 V–DC 60 V / max. 30 A
- Cable cross section max. 10 mm²




fig.14 version PDB-N-CP09A-FF-Ax, pin assignment

pin assignment PDB-N-CP09A-RF-Ax

- line entry see PDB-N-CP09A-RR-Ax
- load terminals see PDB-N-CP09A-FF-Ax

pin assignment PDB-N-CP19A-RR-Ax

- Rear-side supply terminals DC 48 V–DC 60 V / max. 200 A with supply via two supply terminals (internally bridged). Max. 150 A per supply terminal at 50 mm² cable cross section.
- cable cross section max. 50 mm² per supply line
- cable cross section max. 4 mm² with wire end ferrule per load terminal




fig. 15 version PDB-N-CP19A-RR-A, pin assignment (cable grip installed)

3.8 Installation and start-up of the *Power-D-Box*[®]

The *ControlPlex*[®] *Rack* system has been designed for stationary installation in an indoor system cabinet. For installation in an outdoor cabinet we recommend a fully conditioned cabinet with heating and cooling. In the event of high humidity the surrounding has to be additionally dried.

3.8.1 Recommended installation site for *Power-D-Box*[®]

Usually the *Power-D-Box*[®] is installed in the top or bottom area of the system rack. We recommend installation in close proximity to the connected loads so as to reduce wiring and cable management.

Important:



- Leave sufficient space for heat dissipation, min. 0.5U above or below the *Power-D-Box*[®] should be free for ventilation.
- Please take care to install the *Power-D-Box*[®] in enclosed and dry rooms.
- Please observe the required degree of protection.

GENERAL REQUIREMENTS OF INSTALLATION SITE

Various aspects have to be considered when choosing the installation site.

	<p>Ventilation Please ensure sufficient ventilation by leaving enough space at all sides of the device and ensure that the vent holes are not blocked. Leave enough space between the devices.</p>
	<p>Cable management Ensure installation at a site where the cables can be laid and connected properly. Ensure ease of access for service and system extensions of all termination versions even after installation.</p>
	<p>Electrical noise pulses The installation site should provide sufficient distance to any devices that might emit noise pulses.</p>

Table 3: *Power-D-Box*[®] Requirements of installation site

3.8.2 Basic notes on cabling for *Power-D-Box*[®]

The selection of the correct cable types regarding temperature resistance and ampacity is important for the reliable power distribution, control and monitoring by means of a *ControlPlex*[®] *Rack* system. Please ensure to use cables of superior quality with the suitable cross sections so as to avoid voltage drops.

Laying of cables must be carried out carefully. The table 4 gives general hints regarding wiring of a *Power-D-Box*[®], including the connected loads.

Item	Note
1	Cables must be protected against damages and heat. Avoid the proximity to moveable or hot parts and to machines.
2	Ensure a suitable strain relief.
3	Check cables with regard to intact insulation, above all after cable laying.

Table 4: *Power-D-Box*[®] wiring hints

3.8.3 Installation and start-up of the *Power-D-Box*[®]

Important notes








	<p>Danger: Turn off the supply voltage Before beginning with installation, the system has to be disconnected from the mains. A cable connection must only be established if the supply voltage is OFF.</p>
	<p>Caution: Work with ESD protection To protect electronic components against electrostatic voltage, any work must only be carried out with corresponding ESD protection means. Failure to comply can cause damages on the <i>ControlPlex</i>[®] Rack system or the corresponding components.</p>
	<p>Warning: Mounting position The <i>Power-D-Box</i>[®] must only be installed horizontally in the cabinet, vertical installation may cause overheating.</p>
	<p>Warning: Supply voltage The voltage of the power supply must be between DC 38 V and DC 72 V to ensure a smooth operation. In the event of a voltage in excess of DC 75 V the <i>Power-D-Box</i>[®] may be damaged.</p>

Table 5: *Power-D-Box*[®] Important hints for start-up

Start-up of the *Power-D-Box*[®] comprises the following steps:

step	action
1	<p>Prepare all necessary devices and tools such as:</p> <ul style="list-style-type: none"> • different screw drivers and M6 box wrench (not delivered with product) • connecting cables for power supply and ground (not delivered with product) • connecting cables for load terminals (not part of the delivery scope) • 4 mounting screws M6 x 16mm with plastic sleeve • 2 x M6 cable lug, not part of the delivery scope (ground connection <i>Power-D-Box</i>[®]) • load terminal mating plug (can be ordered as accessory for version with front connection, otherwise it is part of the <i>Power-D-Box</i>[®] delivery scope)
2	<p> If installation shall be in an ETSI rack: Re-work of the <i>Power-D-Box</i>[®] mounting brackets to ETSI dimensions: remove, turn bracket by 180°, re-fit with the 2 mounting screws.</p>
3	<p> Important: Please ensure that the system is dead-voltage.</p>
4	<p> Lay all necessary cables for grounding, supply and load terminals of the <i>Power-D-Box</i>[®]</p>
5	<p>Connect the load terminal cables with the corresponding load connectors and mark them with the corresponding way no. of the <i>Power-D-Box</i>[®] Important: Do not yet connect the load connectors to the <i>Power-D-Box</i>[®]. Depending on the version, see chapter 3.7 pin assignment Depending on the version, tightening torque of supply terminals, see table 2, "Technical data/supply"</p>
6	<p>Mounting of <i>Power-D-Box</i>[®] in the system cabinet: Install the <i>Power-D-Box</i>[®] horizontally in the system cabinet and fix it with the 4 supplied mounting screws. The tightening torque of the mounting screws is 5.3–5.7 Nm.</p>



7	<p>Connection of the <i>Power-D-Box</i>[®] grounding cable(s): The ground connection is on the rear side of the <i>Power-D-Box</i>[®] (see fig. 15) and is marked with a grounding symbol. In the event of two separate power supplies (redundant system) both ground connections have to be connected with one grounding cable each. The grounding cable can be fixed with an M6 cable lug and the fitted grounding nut with a tightening torque of 6 Nm.</p>
8	<p>Connection of the <i>Power-D-Box</i>[®] supply lines: Depending on the version, see chapter 4.7 pin assignment Depending on the version, tightening torque of supply terminals, see table 2, "Technical data/supply"</p> <p>Important: Do not yet connect any load lines.</p>
9	<p>Switch on the power supply. Check correct polarity with a voltmeter (plus, minus) and the correct voltage value of the power supply terminals. In the event of a failure please remedy before proceeding with step 10.</p>
10	<p> For installation of circuit protectors, go to chapter 4 "<i>ControlPlex</i>[®] Rack, electronic circuit protector ESX300-S"</p>
11	<p> For installation as group alarm indicator (population without circuit protectors, only with alarm interface EAI300) please go to chapter 7 "<i>ControlPlex</i>[®] Rack, E/A external alarm interface EAI300"</p>
	<p>End</p>

Table 6: *Power-D-Box*[®] steps for start-up

4 General: *ControlPlex*[®] Rack, electronic circuit protector ESX300-S

The electronic circuit protector ESX300-S has particularly designed for the use in the *Power-D-Box*[®] of type PDB-N-CP. It can be installed and de-installed with the system live without having to disconnect the application from the mains. Thus you can reduce the installation and service periods to a minimum.

4.1 Application ESX300-S

The electronic circuit protector ESX300-S is suitable for minus supplied systems with voltage ratings from DC -48 V and DC -60 V. It is capable of disconnecting all faulty loads selectively in the event of overcurrent and short circuit, i.e. without voltage dip or failure of neighbouring loads. In the event of overcurrent or short circuit the active current limitation of the ESX300-S prevents a overload-dependent voltage regulation of the (switched mode) power supply. In the event of a failure the latter prevents a voltage dip of the switch-mode power supply and thus repercussions on the neighbouring loads. The ESX300-S is available both with BUS interface and with potential-free signalling: only for PDB-N-CPxxx-xx-S (old version) The version with BUS interface in connection with the signalling sub-assembly RSI10 (see chapter 5) or with the control interface RCI10 (see chapter 6) allows failure indication as well as an automatic remote control of the ESX300-S via a controlling computer.

4.2 Technical data of ESX300-S

Electronic circuit protectors with active current limitation for use in minus-switching equipment.

Technical data of ESX300-S	
Current ratings	2 A, 5 A, 8 A, 12 A, 16 A, 20 A, 24 A
Capacitive load	max. 7,000 uF (depending on the current rating)
Trip	electronically (1-pole), no physical isolation
Threshold for active current limitation	Typical 1.2 x rated current ESX300-S
Reliability in the event of faulty electronics	integral fail-safe element (blade fuse)
Protected pole	minus pole protected
Operating voltage	DC -37 V to DC -72 V
Signalling (optional)	potential-free auxiliary contacts
BUS system (optional)	EL-BUS [®] for communication with sub-assembly RCI10
Status indication	LEDs red and green
Low voltage indication	< DC -37 V
Overvoltage indication	= / > DC minus 72 V
Trip times	typically < 10 ms at short circuit (current limitation active) typically < 30 sec at overcurrent ($I > I_N < \text{current limitation threshold}$)
Approval logos	CE to EN 61000-6-3 and EN 61000-6-2, UL 2367
Mechanical data ESX300-S	
Ambient temperature	-20 °C ... +60 °C *
Cooling	convection cooling
Mounting position	vertical mounting position
Version	rack module with front plate, no separate enclosure, for installation in <i>Power-D-Boxes</i> [®]

Table 7: ESX300-S, technical data

*) major technical data, for further information please see data sheet of *ControlPlex*[®] Rack

4.2 Current ratings, voltage drop and load capacity ESX300-S

Current rating range I_N	Typical voltage drop U_{ON} at I_N	active current limitation typically	trip time typically at $1.2 \times I_N$	Fail-safe element	max. load current at 100 % ON duty	Max. capacitive load (μ F)
					$T_{AMB} = 40^\circ\text{C}$	
2 A	130 mV	$1.20 \times I_N$	0.2 – 3 s	4 A	2 A	1500
5 A	130 mV	$1.20 \times I_N$	0.2 – 3 s	10 A	5 A	2000
8 A	200 mV	$1.20 \times I_N$	0.2 – 3 s	10 A	8 A	3000
12 A	150 mV	$1.20 \times I_N$	0.2 – 3 s	20 A	12 A	4000
16 A	200 mV	$1.20 \times I_N$	0.2 – 3 s	20 A	16 A	5000
20 A	160 mV	$1.20 \times I_N$	0.2 – 3 s	30 A	20 A	6000
24 A	200 mV	$1.20 \times I_N$	0.2 – 3 s	30 A	24 A	7000

Note: The total current of neighbouring devices must not exceed 44 A.
The derating factor at an ambient temperature of $> 40^\circ\text{C}$ is 0.8 times rated current.

Table 8: ESX300-S, electrical data

4.2.2 LED Status Indication

Operating condition	Load output	LED green	LED red	auxiliary contact N/C (optional)
no error -> OFF	locked	flashing slowly	OFF	open
normal operation	connected	ON	OFF	open
error undervoltage with device in OFF condition ($15\text{ V} < U < 37\text{ V}$)	locked	OFF	ON	closed
error undervoltage with device in OFF condition ($U > 72\text{ V}$)	locked	OFF	ON	closed
overcurrent error detected ($I > I_N < 1.2 \times I_N$) overcurrent failure has to be detected for approx. 30 sec before disconnection is effected	connected	ON	flashing fast	open
error – overcurrent or short circuit disconnection	locked	OFF	ON	closed
error undervoltage ($U > 15\text{ V} < 37\text{ V}$)	connected	ON	ON	closed
error overvoltage ($72\text{ V}, < U < 75\text{ V}$)	connected	ON	ON	closed
error, no voltage or internal error	locked ¹	OFF	OFF	closed
error high temperature	locked ¹	OFF	flashing slowly	closed
remote disconnection (ordering option control interface)	locked	flashing fast	OFF	-----

Table 9: ESX300-S operating conditions - LED display

4.3 Delivery scope ESX300-S

The following parts are part of the delivery scope of the ESX300-S:

- Electronic circuit protector, type: ESX300-S-xxx-xxA with front plate
- removeable label in the front plate

4.4 Picture ESX300-S




fig. 16 ESX300-S electronic circuit protector

4.5 Installation and start-up ESX300-S

Important notes

	<p>Note: <i>Power-D-Box</i>® installed</p> <p>Before starting the installation, the <i>Power-D-Box</i>® has to be properly installed first and supply voltage should be applied. All steps in chapter 3 were carried out properly.</p>
	<p>Caution: Work with ESD protection</p> <p>To protect electronic components against electrostatic voltage, any work must only be carried out with corresponding ESD protection means. Failure to comply can cause damages on the <i>ControlPlex</i>® Rack system or the corresponding components.</p>
	<p>Warning: Mounting position</p> <p>The ESX300-S sub-assembly has to be pushed in vertically into the <i>Power-D-Box</i>®.</p>
	<p>Warning: load terminal</p> <p>Load terminal must be open (not connected) when installing the ESX300-S.</p>
	<p>Warning: Supply voltage</p> <p>The voltage of the power supply must be between DC 38 V and DC 72 V to ensure a smooth operation. In the event of a voltage in excess of DC 75 V the electronic circuit protector may be damaged.</p>

Table 10: ESX300-S, Important hints for start-up

Start-up of the ESX300-S comprises the following steps:





step	action
1	<p>Prepare all necessary devices and tools such as:</p> <ul style="list-style-type: none"> • Electronic circuit protectors ESX300-S (check the ESX300-S with regard to the required current ratings, see chapter 4.5 fig. 16 "rated current value" • For use with PDB-N-CPxxx-xx-Ax (new version of Power-D-Box®), use of bus-capable circuit protectors is mandatory, type ESX300-S-3xx 
2	 <p>Danger: Please ensure that all steps in chapter 3 for starting up the Power-D-Box® are carried out correctly.</p>
3	 <p>Warning: The total current of neighbouring devices must not exceed 44 A. The derating factor is 0.8 times rated current of the ESX300-S with ambient temperatures > 40°C.</p>
4	<p>Installation of the circuit protectors ESX300-S into the Power-D-Box®: Push the ESX300-S with the correct current rating carefully into the related and documented slot (e.g.: slot A1) until it latches on into the front plate in the Power-D-Box®.</p>
5	<p>Check the LED indication of the installed ESX300-S: The status LED "OK" must blink green (load output not yet connected). If the green LED is lighted continuously, push the "On/Off" momentary switch once until it blinks.</p> <p>Important: The red status LED "Fault" must be off. If this is not the case, please go chapter 4.7 ESX300-S trouble-shooting and remedy the failure. Do not continue with step 6 before the LED status indication (both LEDs) is as described in step 5.</p>
6	<p>Connection load output to the corresponding load channel of the Power-D-Box®: Important: Check correct polarity (plus/minus) before connecting. Plug in the load terminal connector pertinent to the installed ESX300-S slot. Example: ESX300-S slot A1 is assigned to load connector A1+ / A1-</p>
7	<p>Switch on the load output of the ESX300-S: Push the momentary switch "On/Off" of the installed circuit protectors ESX300-S. LED status indication: Green LED "OK" is lighted continuously, red LED "fault" is off. If the LED indication is different from the description, please go to chapter 4.7 ESX300-S trouble-shooting.</p>
8	<p>Optional: Individual marking of ESX300-S with a corresponding name. This can be done either on the small label of the ESX300-S or by means of the marking bar available as accessory.</p>
9	<p>Repeat step 1–8 for each ESX300-S to be installed.</p>
10	 <p>Optional: If additional population with E/A external alarm interfaces EAI300, please go to chapter 7 "ControlPlex® Rack, E/A external alarm interface EAI300"</p>
	<p>END</p>

Table 11: Start-up ESX300-S

4.6 Removal of the electronic circuit protector ESX300-S

The electronic circuit protectors can be removed as follows:




step	action
	<p>Caution: Work with ESD protection</p> <p>To protect electronic components against electrostatic voltage, any work must only be carried out with corresponding ESD protection means. Failure to comply can cause damages on the ControlPlex® Rack system or the corresponding components.</p>
1	<p> Important: The ESX300-S has to be in the OFF condition before being removed.</p> <ul style="list-style-type: none"> • Push the momentary switch "On/Off" until the green LED blinks slowly or • disconnect the Power-D-Box® (dead-voltage, both LEDs off)
2	<p> When removing the electronic circuit protector, the interlock at the bottom of the front plate of the circuit protector must be pushed down (see fig. 17).</p>
3	<p>Hold down the interlock and remove the circuit protector by pulling simultaneously at the handles on the top and the bottom of the front plate (see fig. 18).</p>
	END

Table 12: Removal of type ESS30-S...




fig. 17: ESX300-S interlock

fig. 18: ESX300-S removal

4.7 Trouble-shooting concerning electronic circuit protector ESX300-S

The electronic circuit protector ESX300-S has two status LEDs allowing a comprehensive failure analysis in the event of a failure. Please proceed as follows for trouble-shooting:

Important notes

	<p>Caution: Work with ESD protection To protect electronic components against electrostatic voltage, any work must only be carried out with corresponding ESD protection means. Failure to comply can cause damages on the ControlPlex® Rack system or the corresponding components.</p>
	<p>Special precautions must be taken in the system or machine which reliably prevent an automatic re-start of moveable parts of the system (cf. Machinery Directive 98/37/EG and EN 60204-1, Safety of Machinery).</p>
	<p>Note: ESX300-S time after short circuit or overcurrent trip After tripping due to a short circuit, the circuit protector ESX300-S can only be reset after a delay time of approx. 20 seconds.</p>

Table 13: Hints for trouble-shooting for ESX300-S

What to do in the event of a failure

step	action
1	<p>Check status indication of ESX300-S: Check the status of the LEDs of the ESX300-S by table 9, chapter 4.2.2 and put down the cause of the failure</p>
2	<p>Depending on the cause of the failure you can establish physical isolation of the faulty circuit by pulling out the ESX300-S See chapter 4.6 Removal of the electronic circuit protectors.</p>
3	<p>Remedy the cause of the failure As described in step 1, e.g. short circuit on load</p>
4	<p>Re-install the ESX300-S after remedy of the failure See chapter 4.5 Start-up of ESX300-S</p>
	END

Table 14: Trouble-shooting ESS300-S

5 General: **ControlPlex® Rack**, signalling sub-assembly RSI10

The Remote Signalling Interface RSI10 has particularly been designed for use with the **Power-D-Box®** type PDB-N-CPxxx-xx-x in connection with the circuit protector ESX300-S. It can be installed and de-installed with the system live without having to disconnect the application from the mains. Thus you are able to add the RSI10 interface sub-assembly later if required, saving costs and avoiding downtimes.

5.1 Application RSI10

The Remote Signalling Interface RSI10 is designed for an operating voltage of DC 20 V to DC 75 V. It communicates with all other ESX300-S circuit protectors installed in the **Power-D-Box®** via an internal bus. Thus it is possible to realise a potential-free group signalling of alarm messages of the ESX300-S electronic circuit protectors used in the system (version with bus interface. Per supply group of the **Power-D-Box®** the RSI10 provides one each potential-free change-over contact. An integral three-coloured LED additionally indicates failure conditions directly on site. The system can easily be extended at a later date to add the functions remote control, data logging and extended alarm monitoring by means of replacing the RCI10 sub-assembly by RSI10 without a failure of the connected loads.

5.2 Technical data of RSI10

Interface card for group alarm signalling of all circuit protectors installed in the **ControlPlex® Rack**.

Technical data of RSI10	
Operating voltage	DC 20 V...DC 75V
Dielectric strength	DC 100 V for 1 ms
Power consumption	typical 1.2 W
Internal interfaces	ELBus® /power, 20-pole pcb connector
External connection	two plug-in type 3-pole screw terminals with mating plugs Cable cross section: 0.25 mm ² ... 2.5 mm ²
Alarm contact	potential-free change-over contact
Alarm contact max. switching voltage	DC 72 V
Alarm contact Max. switching current	1 A
Alarm contact Max. rupture capacity	60 W / 62.5 VA
Status indication	multicoloured LED (red, green, blue)
Ambient operating temperature	-20° C ... +60° C (without condensation, cf. EN 60204-1)
Storage temperature	-30° C ... +70 °C
Cooling	convection cooling
Mounting position	vertical mounting position
Version	rack module with front plate, no separate enclosure, for installation in Power-D-Box® type PDB-N-CP
Degree of protection	IP00 DIN 40050
Approval logos	CE to EN 61000-6-3 / EN 61000-6-2
Conformity	EN 60950-1 / UL 60950-1 compliant (when installed in PDB)

Table 15: RSI10, technical data

*) major technical data, for further information please see data sheet of **ControlPlex® Rack**

5.2.1 Operating conditions and LED indication

Operating condition circuit protector ESX300-S-3xx	Load output circuit protector ESX300-S-3xx	LED status RSI10 sub-assembly	Auxiliary contact RSI10 sub- assembly group signal "break contact"	status RSI10 sub-assembly
no error -> OFF	locked	green	open	normal operation
normal operation	connected	green	open	normal operation
error undervoltage with device in OFF condition (15 V < U < 37 V)	locked	green	closed	normal operation
error undervoltage with device in OFF condi- tion (U > 72 V)	locked	green	closed	normal operation
Overcurrent error detected ($I > I_N < 1.2 \times I_N$); overcurrent failure has to be detected for approx. 30 sec be- fore disconnection is effected	connected	green	open	normal operation
error – overcurrent or short circuit discon- nection	locked	green	closed	normal operation
error undervoltage (U > 15 V < 37 V)	connected	green	closed	normal operation
error overvoltage (72 V < U < 75 V)	connected	green	closed	normal operation
error: no voltage	locked	OFF (green) ¹	closed	normal duty 1
	locked	green	closed	normal operation
		green	closed	no ESX300-S circuit protector availabe check if ESX300-S bus version is plugged in
-----	-----	red	closed	internal RSI10 error or internal bus error
-----	-----	5 sec blue	open	one new circuit protector ESX300-S was identified

¹ In a redundant system with two supply voltages the green LED lights if only one voltage supply fails, otherwise the RSI10 sub-assembly is dead-voltage

table 16: RSI10, operating conditions – LED

5.3 Delivery scope RSI10

The following parts are part of the delivery scope of the RSI10:

- Remote control interface, type: RSI10-xxx-A with front plate and label including alarm connection mating plug

5.4 Picture of RSI10




fig. 19: RSI10 sub-assembly

5.5 Installation and start-up RSI10

Important notes

	<p>Information: <i>Power-D-Box</i>® and ESX300-S installed Before starting the installation, the <i>Power-D-Box</i>® has to be properly installed first and supply voltage should be applied. All steps in chapter 3.8.3 and chapter 4.5 were carried out properly.</p>
	<p>Caution: work with ESD protection To protect electronic components against electrostatic voltage, any work must only be carried out with corresponding ESD protection means. Failure to comply can cause damages on the <i>ControlPlex</i>® Rack system or the corresponding components.</p>
	<p>Important: Mounting position The RSI10 sub-assembly has to be pushed in vertically into the <i>Power-D-Box</i>® in slot: X0.</p>

Table 17: RSI10, Important hints for start-up

Start-up of the RSI10 sub-assembly comprises the following steps:


step	action
1	<p>Prepare all necessary devices and tools such as:</p> <ul style="list-style-type: none"> • Remote Signalling Interface RSI10 • connecting cables for external alarm signalling
2	<p> Important: Please ensure that all steps in chapter 3 for starting up the <i>Power-D-Box</i>[®] and in chapter 4 "Start-up ESX300-S" were carried out correctly.</p>
4	<p>Installation of the RSI10 sub-assembly into the <i>Power-D-Box</i>[®]: Push the RSI10 sub-assembly carefully into slot X0 and push until latch-on in the front plate in the <i>Power-D-Box</i>[®], see fig. 22.</p>
5	<p>Check the LED indication of the RSI10: The green status LED must be lighted continuously latest after 10 seconds.</p> <p>If this is not the case, please go chapter 5.2.1 LED operating conditions and remedy the failure. Do not continue with step 6 before the green LED is lighted continuously.</p>
6	<p>Connection of an external alarm indication</p> <p>Connect a prepared external alarm indication via the 3-pole alarm contact terminal to the plug of the corresponding screw terminal (C = root; NC = break contact; NO = make contact). An error signal can be indicated via C/NC, an OK signal via C/NO.</p> <p>Split-up group signal of the <i>Power-D-Box</i>[®] for supply group A = upper 3-pole terminal on RSI10</p> <p>Split-up group signal of the <i>Power-D-Box</i>[®] for supply group B = lower 3-pole terminal on RSI10</p> <p>Note: If there is only one supply group on the <i>Power-D-Box</i>[®], the group alarm signal "A" is emitted at both terminal blocks.</p>
7	<p>In the event of an extension with additional circuit protectors The RSI10 LED must be lighted in blue for approx. 5 sec. This means that the newly plugged in circuit protector was identified, see also chapter 5.2.1.</p>
	END

Table 18: RSI10, installation and connection

6 General: **ControlPlex®** Rack, control interface RCI10

The Remote Control Interface RCI10 has particularly been designed for use with the **Power-D-Box®** type PDB-N-CPxxx-xx-A in connection with the circuit protector ESX300-S. It can be installed and de-installed with the system live without having to disconnect the application from the mains. Thus you are able to add the interface sub-assembly later if required, saving costs and avoiding downtimes.

6.1 Application RCI10

The Remote Control Interface RCI10 is designed for an operating voltage of DC 20 V to DC 75 V. It communicates with all circuit protectors type ESX300-S-3xx-xxA (version with BUS interface) installed in the **Power-D-Box®** via an internal BUS. The RCI10 can easily be interconnected with a local LAN network via an external Ethernet interface. Various integral protocols allow a complete automation and remote control of the individual circuit protectors, e.g. ON/OFF operation depending on the voltage or current value. In addition alarm signals and a continuous data recording per query can be forwarded to a connected control computer.

6.2 Technical data of RCI10

Interface card for measuring data recording, automation and remote control of all circuit protectors installed in the **ControlPlex®** Rack.

5.2 Technical data of RCI10	
Operating voltage	DC 20 V...DC 75 V
Dielectric strength	DC 100 V for 1 ms
Power consumption	Typical 2 – 3 W
Internal connection	20-pole pcb connector (EL-BUS, power etc.)
External connection	Ethernet 10 / 100 Base-T, RJ45-connection sleeve for standard network cable of category Cat-5, type "Shielded Twisted Pair"
Status indication	RGB LED (red, green, blue)
Momentary switch	reset and special functions
Supported protocols	SNMP v1, v2c, v3; HTTP, HTTPS, SSH2, DHCP, NTP, IPv4, IPv6
Ambient operating temperature	- 20° C ... +60° C (without condensation, cf. EN 60204-1)
Storage temperature	-30° C ... +70 °C
Cooling	convection cooling
Mounting position	vertical mounting position
Version	rack module with front plate, no separate enclosure, for installation in Power-D-Box®
Degree of protection	IP00 DIN 40050
Approval logos	CE to EN 61000-6-3 / EN 61000-6-2
Conformity	EN 60950-1 / UL 60950-1 compliant (when installed in PDB)

Table 19: RCI10, technical data

*) major technical data, for further information please see data sheet of **ControlPlex®** Rack

6.2.1 LED operating conditions, momentary switch "reset" and failure remedy

"reset" momentary switch	LED colour	LED condition:	importance	description / action
-	green	ON	normal operation	The green LED is lighted continuously when booting is completed and the RCI10 is operating faultlessly. Network connection can be established after another 10 sec.
pushed down for 35 sec	green	blinking	reset IP address to factory settings	By pushing the reset button for 35 seconds, the IP settings can be reset. For visual control that the reset button has been pushed down long enough, the green LED will blink for 5 seconds. Release the momentary switch while the LED blinks, see fig. 19
-	red	ON	internal failure RCI10	The red LED indicates a serious internal failure in the RCI10 sub-assembly. The sub-assembly is no longer operational. By means of a cold boot (remove the sub-assembly - wait for 20 seconds - plug in again) the failure may be remedied. The RCI10 sub-assembly should be replaced nevertheless.
-	red	ON	Serious internal failure BUS (EL-BUS)	The red LED indicates an EL-BUS failure. The communication with the circuit protector ESX300-S and the RCI10 is disrupted. This problem can be caused by a defective circuit protector or a defective RCI10 sub-assembly.
-	blue	ON	Ethernet link available	If a network connection is established in operation (layer 1), the LED will be lighted blue for some 10 seconds.
-	blue	ON	reset IP address to factory settings	The blue LED will be lighted for 10 seconds when the IP address has successfully been reset to factory settings, see fig. 19. Automatic booting will follow, this can last up to 60 seconds.
-	-	OFF	Booting	The RCI10 sub-assembly is booting. Booting can take up to 60 seconds.
-	-	OFF	no supply voltage	No supply voltage or wrong polarity. 1) The voltage supply of the Power-D-Box [®] must at least be DC 20 V. 2) Check polarity of the voltage supply at the Power-D-Box [®] (plus/minus).
pushed down for 3 sec	-	OFF	Warm boot	The system can be reset by pushing the reset button for 3 seconds (warm boot)
	-	OFF	RCI10 sub-assembly defective	If the LED remains unlighted after booting (max. 60 sec), the RCI10 sub-assembly is defective. The sub-assembly must be replaced.

Table 20: RCI10, operating conditions - LED

6.2.2 Function IP-reset by pressing the reset button with LED display




fig. 20: RCI10 IP-Reset

6.3 Delivery scope RCI10

The following parts are part of the delivery scope of the RCI10:

- Remote control interface, type: RCI10-xxx-A with front plate

6.4 Picture of RCI10




fig. 21: RCI10 sub-assembly

6.5 Installation and start-up RCI10

Important notes




	<p>Note: <i>Power-D-Box</i>® and ESX300-S and/or EAI300 installed Before starting the installation, the <i>Power-D-Box</i>® has to be properly installed first and supply voltage should be applied. All steps in chapter 3.8.3, chapter 4.5 and (optional) chapter 7.5 were carried out properly.</p>
	<p>Caution: Work with ESD protection To protect electronic components against electrostatic voltage, any work must only be carried out with corresponding ESD protection means. Failure to comply can cause damages on the <i>ControlPlex</i>® Rack system or the corresponding components.</p>
	<p>Warning: Mounting position The RCI10 sub-assembly has to be pushed in vertically into the <i>Power-D-Box</i>® in slot: X0.</p>

Table 21: RCI10, Important hints for start-up

Installation and connection of the RCI10 sub-assembly comprise the following work steps:




step	action
1	<p>Prepare all necessary devices and tools such as:</p> <ul style="list-style-type: none"> • Remote Control Interface RCI10 • Ethernet cable 10 / 100 Base-T with the correct terminal length
2	<p> Important: Please ensure that all steps in chapter 3 for starting up the <i>Power-D-Box</i>® and in chapter 4 "Start-up ESX300-S" were carried out correctly.</p>
3	<p> Important: Please make sure that any connected signalling cables (group signalling) on the <i>Power-D-Box</i>® are de-installed. Should voltage be applicable here, parts of the <i>ControlPlex</i>® Rack could be destroyed.</p>
4	<p>Installation of the RCI10 sub-assembly into the <i>Power-D-Box</i>®: Push the RCI10 sub-assembly carefully into slot X0 and push until latch-on in the front plate in the <i>Power-D-Box</i>®, see fig. 22.</p>
5	<p>Check the LED indication of the RCI10: The green status LED must be lighted continuously latest after 60 seconds. If this is not the case, please go chapter 6.2.1 LED operating conditions and remedy the failure. Do not continue with step 6 before the green LED is lighted continuously.</p>
6	<p>Connection of Ethernet cable Plug the Ethernet cable into the RJ45 connector of the RCI10 sub-assembly, see fig. 20, and connect it to your internal network or directly with a configuration PC, see fig. 23.</p>
7	<p> Go to chapter 6.6 and configure the RCI10 sub-assembly according to your requirements.</p>
	<p>END</p>

Table 22: RCI10, installation and connection

6.5.1 Picture of slot for RCI10 or RSI10

Information: The slot X0 is at the same position with all PDB-N-CPxxx-xx-x versions, first slot on the left side.



fig. 22: PDB slot X0

6.5.2 Picture of an example for network connection




Fig. 23: connection example network

6.6 Configuration and start-up RCI10

For configuring the RCI10 sub-assembly you need the **ControlPlex® Rack** Operation Instruction RCI10.

In order to establish a logic connection in your LAN network with a configuration PC, the RCI10 sub-assembly has to be connected with the PC via an Ethernet cable, see fig. 23.

The document **ControlPlex® Rack** Operation instruction RCI10 is available on our website:

www.e-t-a.de/controlplex_rack

7 General: *ControlPlex*[®] Rack, E/A external alarm interface EAI300

The EAI300 has particularly been designed for use with the *Power-D-Box*[®] type PDB-N-CP in connection with the remote control interface RCI10. It can be installed and de-installed in the *Power-D-Box*[®] later with the system live without having to disconnect the application from the mains. The EAI300 only requires a free ESX300 slot (slot for circuit protectors) in the *Power-D-Box*[®].

7.1 Operating mode and application EAI300

The EAI300 has been conceived for connection and free text indication of alarm messages from “external” alarm contacts and sensors in the plant room by means of a control computer. This could include door contacts, temperature sensors or alarm contacts of the air conditioning system. The EAI300 interface communicates with the RCI10 Remote Control Interface installed in the *Power-D-Box*[®] via an internal bus. The RCI10 sub-assembly communicates with a management system or a control computer by means of an Ethernet interface. With the help of an integral LED an “external” alarm can also be indicated locally on the EAI300. An integral 24V voltage output can be used directly for reading the alarm contacts. Equally, there are two potential-free outputs available for activating e.g. a door lock or for realising an additional group signalling of the ESX300 circuit protectors. Within a *Power-D-Box*[®] you can install up to 20 EAI300 sub-assemblies.

7.2 Technical data of EAI300

Interface card for forwarding additional alarms in the engineering room, so-called “external alarms”.

Technical data of EAI300	
Operating voltage	DC 20 V ... DC 75 V
Dielectric strength	DC 100 V for 1 ms
Power consumption	Typically 1.9 W
Internal interfaces	EL-Bus [®] and supply via blade terminals
External connection	Two plug-in type 8-pole connection sleeves with spring-loaded connectors on the front side Cross-section 0.14 mm ² ... 1.5 mm ²
Number of digital inputs:	Eight physically isolated inputs
Current consumption	1 mA at 24 V
Input resistance:	22.1 kOhm
Voltage potential “HIGH” level	DC 12 V ... DC 72 V
Voltage potential “LOW” level	DC 0 V ... DC 4 V
Number of analog inputs:	One physically isolated input
Measuring input	4 mA ... 20 mA
Number of digital outputs (relay outputs)	Two physically isolated relay outputs (break contacts)
Max. load current of contact	2 A
Voltage range – contact	DC 12 V ... DC 72 V
Internal supply voltage for I/O connection	Typically DC 24 V (at Power-D-Box supply voltage ≥ DC 30 V)
Max. load current:	100 mA

External supply voltage for I/O connection	DC 12 V ... DC 72 V
Max. number of EAI300 sub-assemblies per Power-D-Box® and RCI10 sub-assembly	20 (depending on Power-D-Box® type)

Table 23: EAI300, technical data

*) major technical data, for further information please see data sheet of **ControlPlex® Rack**

7.2.1 Operating conditions LED signalling

Operating condition EAI300	LED indication EAI300
EAI300 normal duty	green
EAI300 normal duty: digital input has status "High"	green / cyan blue blinking
EAI300 normal duty: identified new circuit protector ESX300 (relay output configured as group signal)	5 seconds blue
EAI300 fault condition: no control interface RCI10 available	red blinking
EAI300 fault condition: EAI300 internal fault	red
EAI300 fault condition: no RCI10 available and digital input on status "High"	red / cyan blue blinking


Table 24: EAI300, operating conditions – LED

7.3 Delivery scope EAI300

The following parts are standard part of the delivery scope of the EAI300:

- External Alarm Interface, type: EAI300-xxx-A with front plate including spring force mating plugs
- Accessories: 16 labels and coding pin for spring force mating plugs

7.4 Picture EAI300



7.5 Installation and connection EAI300

Important notes






	<p>Note: <i>Power-D-Box</i>® and additional sub-assemblies installed</p> <p>Before starting the installation, the <i>Power-D-Box</i>® has to be properly installed first and supply voltage should be applied. All steps in chapter 3 were carried out properly.</p>
	<p>Caution: Work with ESD protection</p> <p>To protect electronic components against electrostatic voltage, any work must only be carried out with corresponding ESD protection means. Failure to comply can cause damages on the <i>ControlPlex</i>® Rack system or the corresponding components.</p>
	<p>Warning: Mounting position</p> <p>The EAI300 sub-assembly has to be pushed in vertically into the <i>Power-D-Box</i>®.</p>

Table 25: EAI300, Important hints for start-up

Installation and connection of the EAI300 sub-assembly comprise the following work steps:

step	action
1	<p>Prepare all necessary devices and tools such as:</p> <ul style="list-style-type: none"> • External Alarm Interface EAI300 and accessories • connecting cables for external Alarm Interface • Probably a distribution terminal is required
2	<p> Important: Please ensure that all steps in chapter 3 for starting up the <i>Power-D-Box</i>® and in chapter 4 "Start-up ESX300-S" were carried out correctly.</p>
3	<p> Important: INSTALLATION POSITION</p> <p>When using the EAI300 together with ESX300 circuit protectors within one <i>Power-D-Box</i>®, the EAI300 should always be plugged into the highest slot of the <i>Power-D-Box</i>®, e.g. with <i>Power-D-Box</i> type: PDB-N-CP19A... into slot 19, the following EAI300 into slot 18 etc.</p>
4	<p>Installation of the EAI300 sub-assembly into the <i>Power-D-Box</i>®:</p> <p>Push the EAI300 sub-assembly carefully into the corresponding slot and push until latch-on in the front plate in the <i>Power-D-Box</i>®, see fig. 7.5.1 "Example EAI300 slot configuration"</p>
5	<p>Check the LED indication of the EAI300:</p> <ol style="list-style-type: none"> 1. RC110 sub-assembly already pre-installed: The green status LED must be lighted continuously. 2. RC110 sub-assembly not installed: The red status LED must be blinking. <p>If this is not the case, please go chapter 7.2.1 LED operating conditions and remedy the failure. Do not continue with the next step before the LED status indication shows the correct condition.</p>
6	<p>Plug coding and plug numbering</p> <p>Please code the plug X5 and number the contacts of the plugs X5 and X6 with the supplied accessory set, see chapter 7.5.2 "EAI300 pin assignment and connection example"</p>
7	<p>Connection of "external" alarm contacts</p> <p>Connect the "external" alarm contacts / alarm outputs with the appropriate terminals via the connectors of the EAI300, please see chapter 7.5.2 "EAI300 connection example"</p>
8	<p>Please record each connected alarm contact</p> <p>You will require this information later for the logical assignment of the alarms (software configuration)</p> <p>Example: "Door contact cabinet 1 = PDBxx- slot A19 / digital input 1"</p>
9	<p>Repeat step 1–8 for each EAI300 to be installed.</p>





10	 No RCI10 sub-assembly pre-installed Please go to chapter 6 and install the RCI10 sub-assembly.
11	 RCI10 sub-assembly pre-installed Go to chapter 7.6 and configure the EAI300 sub-assembly according to your requirements.
	END

Table 26: EAI300, installation and connection

7.5.1 Example: EAI300 slot configuration (mixed population with ESX300 and EAI300)



7.5.2 EAI300 pin assignment and connection example



7.6 Configuration and start-up EAI300

For configuring the EAI300 sub-assembly you need the **ControlPlex® Rack Operation Instruction RCI10**.

The document "Operation instruction Remote Control Interface RCI10" is available on our website:
www.e-t-a.de/controlplex Rack.



ENGINEERING TECHNOLOGY